



RAUCH

Phone: (718) 507-8844 Fax: (718) 565-6018
 Email: info@irauch.com
 Address: 32-20 112th St, East Elmhurst, NY 11369

Fig 100S: Clevis Hanger with Welded Saddle



Material: Steel
Service Application: Designed to properly support insulated lines not subject to Longitudinal Movement.
Finish: Black, galvanized, or painted.
Ordering: Specify size, figure number, thickness of covering, and finish.



HANGER SIZING GUIDE						
THICKNESS OF PIPE INSULATION						
PIPE SIZE	1/2"	1"	1 1/2"	2"	2 1/2"	3"
1/2	1 1/2	2 1/2	3 1/2	5	6	7
3/4	2	3	3 1/2	5	6	7
1	2	3	4	5	6	7
1 1/4	2 1/2	3 1/2	4	5	6	7
1 1/2	2 1/2	3 1/2	5	6	7	8
2	3	4	5	6	7	8
2 1/2	3 1/2	5	6	7	8	10
3	4	5	6	7	8	10
3 1/2	5	6	7	8	10	10
4	5	6	7	8	10	10
5	6	7	8	10	10	12
6	7	8	10	10	12	12

PROJECT INFORMATION	APPROVED
JOB:	NOTES:
ADDRESS:	
CONTRACTOR:	
ENGINEER:	
DATE:	
APPROVED _____ NOT APPROVED _____ APPROVED AS NOTED _____	